

**DIRECTORATE OF ENFORCEMENT, VIGILANCE & DISASTER MANAGEMENT  
GREATER HYDERABAD MUNICIPAL CORPORATION**

From  
The Director,  
Enforcement, Vigilance  
Disaster Management,  
GHMC, Hyderabad.



To  
The Correspondent,  
Podar International School,  
Sy. No. 27, Anmagal, Hayathnagar(V),  
Hayathnagar (M),  
Ranga Reddy District.

Rs. No. DM/0434/2023, Dated: 26.10.2023.

Sub :- Directorate of EV&DM - GHMC - Existing non high-rise building of Podar International School consisting of Ground Floor, situated at Sy. No. 27, Anmagal, Hayathnagar(V), Hayathnagar (M), Ranga Reddy District - Renewal of Fire No Objection Certificate - Issued - Regarding.

- Ref :-
- 1) Proceeding Rc. No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services, A.P., Hyd.
  - 2) Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt 29.06.2018 of the Commissioner, GHMC
  - 3) Fire No Objection Certificate for Occupancy issued vide Rc.No.DM/0164/2022, dated. 01.04.2022.
  - 4) Application of the Management, Dated: 16.10.2023.
  - 5) E-office No. 339690 & file No.DM/0434/2023 of the Director, EV&DM.
  - 6) Inspection report dated: 26.10.2023.

\*\*\* \*\*

Vide reference 3<sup>rd</sup> cited, the renewal of Fire No Objection Certificate for Occupancy was issued to the existing non high-rise building of Podar International School consisting of Ground Floor, situated at Sy. No. 27, Anmagal, Hayathnagar(V), Hayathnagar (M), Ranga Reddy District. Vide reference above 4<sup>th</sup> cited, the management has applied now, for renewal of Fire No Objection Certificate.

Vide reference 6<sup>th</sup> cited, the team has inspected the above building and submitted the report of the as under:

2. Particulars of the Building:

a)	Name & Address of the building	Podar International School Sy. No. 27, Anmagal, Hayathnagar(V), Hayathnagar (M), Ranga Reddy District
b)	Plot Area/Height	6070.29 Sq. Meters/4.40 Meters
d)	No of floors	Ground Floor only
e)	Name of the Owner & Mobile no.	Correspondent - A Ramgopal Krishna, Ph. No. 9324916088
f)	Map Location	17.399753 78.538924

:: 2 ::

## 3. Floor wise details:

Sl. No.	Floor	Area in Sq. Meters	Type of Occupancy	Max Occupant Load
1	Ground Floor	1424.76	Educational (School, B-1)	356
	Total	1424.76	-	-

## 4. Open Spaces All Round Building:

Sl. No.	Directions	Required as per NBC	Provided	Deficit
1	Front (East)	6.00 Meters	6.00 Meters	Nil
2	Side-I (North)	6.00 Meters	6.00 Meters	Nil
3	Side-II(South)	6.00 Meters	6.00 Meters	Nil
4	Rear (West)	6.00 Meters	6.00 Meters	Nil

## 5. Means of escape:

Sl. No	Floor	Description	Minimum MOE Required		Provided		Deficit
					Nos.	Width	
1	Ground Floor	Door Ways	Doors width: 2.31 Meters		04	2 X 2.00 Meters 2 X 1.50 Meters Total = 7.00 Meters	Nil
		Internal / External Staircases	Nos.	Width	04	2 X 2.00 Meters (Ground to terrace) 2 X 1.50 Meters (Ground to terrace) Total = 7.00 Meters	Nil
			0	0			

## 6. The Fire Safety Installations required &amp; provided by the builder as per the Table 7 of Part-4 of N.B.C of India 2016.

Sl. No	Fire Safety Installations	Required	Provided	Deficit
1	Fire Extinguishers	15 Nos.	15 Nos.	Nil
2	First Aid Hose Reel	02 Nos.	04 Nos.	Nil
3	Down Comer	NR	02 Nos.	Nil
4	Manually Operated Electronic Fire Alarm Systems	NR	02 Nos.	Nil
5	Terrace Water Tank	10,000 Liters	10,000 Liters	Nil
6	Pump at the Terrace Tank Level	1 No. Booster pump of 450 LPM	1 No. Booster pump of 900 LPM	Nil

**Terms & Conditions: -**

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules /Govt. Orders as applicable.
2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.



:: 3 ::

3. No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
4. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
5. Every room with a capacity of 45 students (for educational building) shall be provided with two doorways.
6. Every vertical opening between the floors of the building shall be suitably enclosed or protected to prevent spread of fire, smoke and fumes from one floor to other.
7. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
8. Fresh NOC would be required for any change in occupancy or additions/ alterations in the building structure as per NBC of India and building bye/laws.
9. The Management has to maintain the Fire Fighting systems at all times in good working Condition, as seen during the inspection.
10. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
11. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
12. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
13. This Order will be without any prejudice to take action against the Unauthorized construction if any made.
14. This renewal of Fire No Objection Certificate is valid for one year from the date of issue and it the responsibility of the builder/occupier to apply for the next renewal, two months before the expiry of this Fire NOC.

In view of the above, the Renewal of Fire No Objection Certificate is issued to the existing non high-rise building of Podar International School consisting of Ground Floor, situated at Sy. No. 27, Anmagal, Hayathnagar(V), Hayathnagar (M), Ranga Reddy District.

DIRECTOR,  
EV & DM, GHMC

Signed by Nyalakonda  
Prakash Reddy  
Date: 28-10-2023 16:59:29  
Reason: Approved