



Junagadh Municipal Corporation

"Swami Vivekanand Bhavan", Azad chock, Junagadh. – 362001

Phone No. 0285-2622089, Fax No. 0285-2651510

E-Mail : firedepartmentjmc@gmail.com



Ju.M.N.P./Fire/Outward No. 1442/24

Date: 21 - 03 - 2024

To,

**Podar International School – Junagadh,
Survey No. 44/1, B/H. Mahasagar Petrol Pump,
Junagadh-Rajkot Highway, Village: Sukhpur,
Taluka & Dist: Junagadh. 362310 (Gujarat)
Phone: 8291002394, 7574807039**


Subject: - NOC No. JuMC/Fire/NOC/Outward/27, Date: 5/7/2022.

Ref: - Your Letter, Inward No. 1463/24, Dated. 19/3/2024.

With reference to the above-cited subjected reference letter, kindly find the details as per the Fire Plan Prepared by Fire Protection Consultant and submitted by you to this office to proceed the Subjected task.

Particular	B.A. in SQ MT
Ground Floor	953.41
First Floor	953.41
Second Floor	953.41
Total	2860.23

The above details is as per the documents submitted by proprietor at the time of applying of Fire NOC. This office does not liable for any changes made then after of the said building. This is for your kind consent please.


**Chief Fire Officer,
Municipal Corporation,
Junagadh.**

Dipak Jani



**PRINCIPAL
PODAR INTERNATIONAL SCHOOL
JUNAGADH-362 310**


**General Manager
(Saurashtra Region)
Podar International School**



JUNAGADH MUNICIPAL CORPORATION FIRE & EMERGENCY SERVICES

"SWAMI VIVEKANAND BHAVAN", AZAD CHOWK, JUNAGADH-362001
PH.No. 0285-2622089, FAX No. 0285-2651510
E-mai :municipalcorporationjund@yahoo.co.in



Ju.M.C./Fire/Noc/Outward/No. 29

Date:- 4/09/2022

NO OBJECTION CERTIFICATE

This is to certify that the management of Podar International School Located at Near Mahasagar Petrol Pump Junagadh Rajkot Highway, Junagadh has provided adequate Fire Protection measures.

The Fire Department has NO OBJECTION to the said premises as required level of Fire Protection is provided as under.

Sr. No.	Item Name	Number Of Item
1	5 kg capacity ABC type Fire Extinguishers	15
2	4 kg capacity ABC type Fire Extinguishers	8
3	2 kg & 4.5 kg Capacity CO2 type Fire Extinguishers	8
4	Hose Reel	Each Floor
5	Hose Box	Each Floor
6	Fire Pump 7.5 HP	01
7	Fire Alarm Penal	01
8	Fire Inlet (2 Way)	01
9	Pump On Of Switch	Each Floor


All Extinguishers / items shall be maintained in working order throughout the validity period of this certificate. (* if you can't complete all works within 30 days which is suggested by fire officer, than this NOC is automatically be invalid.)

This Certificate is valid till Three Year



Chief Fire Officer
Municipal Corporation,
Junagadh

Dipak Jani


PRINCIPAL

PODAR INTERNATIONAL SCHOOL
JUNAGADH-362 310


General Manager
(Saurashtra Region)
Podar International School